



ATC
06-010

AKREDITOVANA
KONTROLNA
ORGANIZACIJA

SRPS ISO/IEC 17020:2002

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number:

T 1034

Strana / Page:

1/2

Na zahtev naručioca /
By the request of purchaser:

Robert Bosch d.o.o. ; Milutina Milankovića 11a ; Beograd
Srbija/Serbia

preduzeto je/
set to:

kontrolisanje novog proizvoda
the new product inspection

u vezi sa Izveštajem o kontrolisanju /
in relation to Inspection report:

Broj / Number:

T 1034

sa dokumentima u prilogu/
with enclosed documents:

- Prospekt proizvoda /
Catalogue pages of product;
- Uputstvo za instaliranje i korišćenje /
Installation and user's manual;
- Izveštaj o ispitivanju IMP-CGT-LAB broj T 1034 /
Test report by IMP-CGT-LAB No. T 1034

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja /
the inspection object :

GASNI KONDENZACIONI KOTAO
GAS CONDENSING BOILER

proizveden od /
manufactured by :

Bosch Thermotechnik GmbH

oznaka - tip - serija /
mark - type - series :

BOSCH CONDENS 5000 W ZBR ...

vrsta/type: B_{23(P)}, C_{13(X)}, C_{33(X)}, C_{43(X)}, C_{53(X)}
kategorija/category: П_{2H3P}

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements sa decribed in :

referentnom dokumentu /
reference document :

SRPS M.E6.300:1994; EN 483:1999; EN 677:1998

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2002 .
The inspection certificate is issued basis on the standard SRPS ISO/IEC 17020:2002 .

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa
periodičnim kontrolisanjem do dana /

Surveillance of the inspection object compliance is assured by periodical
inspection until the date :

01.11.2015

Sertifikat o kontrolisanju
Inspection certificate



izdat od / issued by :

za RUKOVODIOCA CENTRA ZA GASNU TEHNIKU
instead of the GAS TECHNIQUE CENTRE MANAGER

mesto, datum / place, date

Beograd, 02.11.2010

Dejan Simonović, dipl. ing.

Ime , Prezime / Name , Surname

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number:

T 1034

Strana / Page:

2/2

Prilog A /

Annex A

oznaka - tip - serija /
mark - type - series :

BOSCH CONDENS 5000 W ZBR ...

vrsta/type: **B_{23(P)}, C_{13(X)}, C_{33(X)}, C_{43(X)}, C_{53(X)}**
kategorija/category: **II_{2H3P}**

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
BOSCH CONDENS 5000 W		
ZBR 65-2	2H: p=20 mbar Q _n =14,6÷62,0 kW (Hi) P _n =14,2÷60,4 kW ^{1.)} PMS=4 bar, T=90°C 3P: p=50 mbar 230 V, 50 Hz, IP X4D, IP X0D ^{2.)} NO _x : 5, η : ★★★★★	zidni gasni kondenzacioni kotao- / wall hung gas condensing boiler -
98-2	2H: p=20 mbar Q _n =19,3÷95,0 kW (Hi) P _n =18,6÷92,1 kW ^{1.)} PMS=4 bar, T=90°C 3P: p=50 mbar 230 V, 50 Hz, IP X4D, IP X0D ^{2.)} NO _x : 5, η : ★★★★★	
Napomene / notes: 1.) pri / at: t ₂ /t ₁ =80/60°C; 2.) samo za / only for: B _{23(P)} .		

Sertifikat o kontrolisanju Inspection certificate